

Installing The Fusible Links Or Thermo Bulb Links

Detectors should be at the location nearest onto airflow way of hood for the best results. Positioning tolerance is 10 cm. for each direction.

Please see the figures below.

Detection wire shall be bended as seen on figures and fixed with aluminum collet.

"S hooks" shall be used to hold the detectors.

Detection line total Length is maximum 20 m.

Total maximum bends in the detection line is 18 units.

Maximum detector installation height is 160 cm. from max height of appliance surface.


Minimum detector installation height is 125 cm. from max height of appliance surface.

Fire detection distance of each detector is 120 cm. Location tolerance is 10 cm. for each direction.

For fast fire detection, detectors are to be located up of the cooking device and at the direction of the smoke discharge of the cooking device.

In order to prevent accidental activation of the system, it should be towards the channel outlet and at the required height.

Installation Of Thermo Bulb Link:



Thermo Bulb Link Installation Example:

